

**Operating Instructions
for
Thermal Mass Flowmeter
for gases**

Model: KEC-2/KEC-4



I. Foreword

Dear customer,

thank you very much for deciding in favour of the KEC-2/KEC-4. Please read this installation and operation manual carefully before mounting and initiating the device and follow our advice. A riskless operation and a correct functioning of the KEC-2/KEC-4 are only guaranteed in case of careful observation of the described instructions and notes



The instruction manuals on our website www.kobold.com are always for currently manufactured version of our products. Due to technical changes, the instruction manuals available online may not always correspond to the product version you have purchased. If you need an instruction manual that corresponds to the purchased product version, you can request it from us free of charge by email (info.de@kobold.com) in PDF format, specifying the relevant invoice number and serial number. If you wish, the operating instructions can also be sent to you by post in paper form against an applicable postage fee.

Manufactured and sold by:

Kobold Messring GmbH
Nordring 22-24
D-65719 Hofheim
Tel.: +49(0)6192-2990
Fax: +49(0)6192-23398
E-Mail: info.de@kobold.com
Internet: www.kobold.com

II. Table of Content

I. Foreword	2
II. Table of Content	3
1 Pictograms and Symbols	5
2 Signalwords according ISO 3864 and ANSI Z 535	5
3 Safety instructions.....	6
3.1 Intended Use.....	7
3.2 Installation and commissioning	7
4 Technical Information.....	8
5 Order Codes	8
6 Dimensions	8
6.1 Signal circuits.....	8
6.1.1 Modbus	8
6.1.2 Current output.....	8
6.1.2.1 Active	8
6.1.2.2 Passive	8
6.1.2.3 Pulse	8
6.1.2.4 Alarm	8
6.2 Measuring range flow KEC-2/KEC-4	9
6.2.1 Measuring range end values "Low Speed".....	9
6.2.2 Measuring range end values "Standard Version"	10
6.2.3 Measuring range end values "Max Speed Version"	11
6.2.4 Measuring range end values "High-Speed Version".....	12
7 Dimensions	13
7.1 Dimension KEC-2/KEC-4 Thread-version	13
7.2 Dimension KEC-2/KEC-4Flanged-version	14
8 Installation.....	15
8.1 Pipe/tube requirements	15
8.2 Inlet / outlet runs	15
8.2.1 Installation of KEC-2/KEC-4	17
8.3 Alignment Display (Housing).....	17
8.4 Tightening torques.....	17
9 Connection diagram	18
9.1 Cable glands - clamping ranges	18
9.2 Connector pin assignment.....	18
9.3 Wire connection	20
9.3.1 General	20
9.3.2 Power supply	20
9.3.3 Modbus RTU.....	20
9.3.4 Pulse Output	20

10 Operation KEC-2/KEC-4	21
10.1 Main menu (Home).....	21
10.1.1 Initialization	21
10.2 Main menu	22
10.3 Settings	22
10.3.1 Sensor Setup	23
10.3.1.1 Input / change tube diameter.....	23
10.3.1.2 Input / change consumption counter	24
10.3.1.3 Definition of the units for flow, velocity, temperature and pressure	24
10.3.1.4 Definition of the reference conditions	25
10.3.1.5 Setting of Zeropoint and Low-flow cut off.....	27
10.3.2 Modbus Setup.....	29
10.3.2.1 Modbus Settings (2001...2005).....	30
10.3.2.2 Values Register (1001 ...1500)	31
Remark:.....	32
10.3.3 Pulse /Alarm.....	33
10.3.3.1 Pulse output.....	33
10.3.4 User Setup	34
10.3.5 Advanced	35
10.3.6 4 -20mA	36
10.3.7 KEC-2/KEC-4 Info.....	38
11 Disposal	39
12 EU Declaration of Conformance	40
13 UK Declaration of Conformity.....	42

1 Pictograms and Symbols



General Warning symbol (Danger, Warning, Caution)



General note



Installation- and Instruction manual to consider (on Nameplate)



Installation- and Instruction manual to consider

2 Signalwords according ISO 3864 and ANSI Z 535

Danger!	Imminent danger As a consequence of incorrect handling: serious personal injury or death
Warning!	Possible hazard As a consequence of incorrect handling: possible serious injury or death
Caution!	Imminent hazard As a consequence of incorrect handling: possible personal injury or damage
Note!	Possible hazard As a consequence of incorrect handling: possible personal injury or damage
Important!	Additional notes, information, tips As a consequence of incorrect handling: Disadvantages in operation and maintenance, no danger

3 Safety instructions



Please check whether this manual corresponds with the device type.

Please attend to all notes indicated in this instruction manual. It contains essential information, which has to be followed during installation, operation and maintenance. Therefore this instruction manual has to be read categorically by the technician as well as by the responsible user/qualified personnel before installation, initiation and maintenance

Regional and national regulations respectively, have to be observed in addition to this instruction manual if necessary.

This instruction manual has to be available at any time at the operation site of the DS 500.

Ensure that the KEC-2/KEC-4 operates within the permissible and listed limits on the nameplate. Otherwise there is a risk to human and material, and it may occur functional and operational disturbances

In case of any obscurities or questions with regard to this manual or the instrument please contact Kobold GmbH..



Warning!

Risk of injury in case of inadequate qualification!

Improper handling can result in significant personal injury and damage.

All activities described in this operating instructions manual must be carried out only by qualified personnel qualifications described below.

Professionals (Technical staff)

The technical staff is based on his education/training, his knowledge of measurement and control technology as well of the local regulations, standards and guidelines in the position to do the work as described and to identify the possible hazards.

Special working conditions require further appropriate knowledge, e.g. of aggressive media.



Caution!

Malfunction of KEC-2/KEC-4

Faulty installation and insufficient maintenance may lead to malfunctions of the KEC-2/KEC-4 which may affect the display and open to misinterpretation.

Danger!



Inadmissible operating parameters!

By exceeding or falling short of limits there is a risk for people and material, in addition there may occur further functional and operational disturbances.

Measures:

- Make sure that the KEC-2/KEC-4 operates only within the permissible and listed limits on the nameplate
- Ensure the operation within the performance data of KEC-2/KEC-4 in connection with the application
- Do not exceed the admissible storage and transportation temperature.

Additional safety information:

- When installing and operating the relevant national regulations and safety rules must also be observed.

3.1 Intended Use

The instrument described in this manual is exclusively to use for measuring the thermal mass flow of gases. At the same time, the gas temperature is measured too. The KEC-2/KEC-4 can be configured for measuring a predetermined range of pure gases or of gas mixtures.

Consumption measurement of gases such as air, oxygen, nitrogen, carbon dioxide, argon, etc. and with ATEX approval explosive gases such as natural gas, methane, propane and hydrogen.

Improper or incorrect use the operational reliability will be canceled. The manufacturer is not liable for any damage resulting by improper or incorrect use.

3.2 Installation and commissioning

- Installation, electrical installation, commissioning, operation and maintenance of the device must only be carried by qualified personnel, which were authorized by the plant operator.
The personnel must read the operating instructions and understand and follow their instructions.
- If carrying out welding work on the pipeline the grounding of the welding unit is not allowed to be done over the KEC-2/KEC-4 itself.
- The installer has to ensure that the KEC-2/KEC-4 is connected according to the electrical connection diagrams properly. The sensor must be grounded, unless special protective measures have been taken (e.g. galvanically isolated power supply)
- The existing/ applicable national regulations governing opening and repair of the device have to be applied.
- When using the KEC-4 (ATEX Version) hazardous areas, in addition with the standard manual a separate Ex documentation is enclosed. The installation instructions and connection values indicated in these must also be observed.
- The device fulfills the general safety requirements in accordance with EN 61010-1, the EMC requirements of IEC / EN 61326 and NAMUR recommendation NE 43.

4 Technical Information

Operating instructions, data sheet, approvals and further information via the QR code on the device or via www.kobold.com

5 Order Codes

Operating instructions, data sheet, approvals and further information via the QR code on the device or via www.kobold.com

6 Dimensions

Operating instructions, data sheet, approvals and further information via the QR code on the device or via www.kobold.com

6.1 Signal circuits

6.1.1 Modbus

- According Standard EIA/TIA-485

6.1.2 Current output

6.1.2.1 Active

- Galvanically isolated
- 4 ... 20 mA
- $R_L < 500 \text{ Ohm}$

6.1.2.2 Passive

- Galvanically isolated
- 4 ... 20 mA
- $R_L < 500 \text{ Ohm}$
- $V_{in} 12-36 \text{ Vdc}$

6.1.2.3 Pulse

- Galvanically isolated (dry contact)
- Passive: 48 Vdc , 500 mA
- Max. pulse output freq. 50 Hz

6.1.2.4 Alarm

- Galvanically isolated (dry contact)
- Max. 48 Vdc, 500 mA

6.2 Measuring range flow KEC-2/KEC-4

6.2.1 Measuring range end values “Low Speed”

Measuring ranges low-speed version

Inside diameter of pipe			Low-speed version (50 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Air**	Nitrogen (N ₂)	Argon (Ar)	Oxygen (O ₂)	Carbon dioxide (CO ₂)	Methane natural gas (CH ₄)	Helium (He)	Hydrogen (H ₂)	Propane (C ₃ H ₈)
½"	16.1	DN 15	20 [14.4]	20 [13.2]	35 [20]	20 [13.5]	20 [14.1]	240 NI/min [8.4]	170 NI/min [6]	120 NI/min [4.2]	185 NI/min [6.6]
¾"	21.7	DN 20	45 [25]	40 [25]	75 [40]	45 [25]	45 [25]	25 [15]	20 [11.7]	235 NI/min [8.1]	20 [12.9]
1"	27.3	DN 25	75 [45]	70 [40]	120 [70]	75 [40]	75 [45]	45 [25]	30 [15]	20 [13.5]	35 [20]
1 ¼"	36.0	DN 32	140 [80]	130 [75]	220 [130]	135 [80]	140 [80]	85 [50]	60 [35]	40 [20]	65 [35]
1 ½"	41.9	DN 40	195 [115]	180 [105]	305 [180]	185 [110]	195 [115]	115 [65]	80 [45]	55 [30]	90 [50]
2"	53.1	DN 50	320 [190]	295 [175]	505 [295]	305 [180]	320 [185]	190 [110]	135 [75]	95 [55]	145 [85]
2 ½"	68.9	DN 65	550 [325]	505 [300]	865 [510]	525 [310]	545 [320]	325 [190]	230 [135]	160 [95]	250 [150]
3"	80.9	DN 80	765 [450]	705 [415]	1200 [705]	730 [430]	760 [445]	450 [265]	320 [185]	225 [130]	350 [205]

Measuring ranges low-speed version (continued)

Inside diameter of pipe			Low-speed version (50 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Corgon ®18	Forming gas 90% N ₂ + 10% H ₂	Natural gas (NG)	Biogas 50% CH ₄ + 50% CO ₂	Biogas 60% CH ₄ + 40% CO ₂	LPG 60% C ₃ H ₈ + 40% C ₄ H ₁₀	LPG 50% C ₃ H ₈ + 50% C ₄ H ₁₀	Nitrous oxide (N ₂ O)	Ethyne/ Acetylene (C ₂ H ₂)
½"	16.1	DN 15	35 [20]	20 [12]	15 [9]	15 [10.5]	15 [10.2]	215 NI/min [7.5]	210 NI/min [7.5]	20 [14.1]	225 NI/min [8.1]
¾"	21.7	DN 20	70 [40]	40 [20]	30 [15]	30 [20]	30 [20]	25 [15]	25 [14.7]	45 [25]	25 [15]
1"	27.3	DN 25	115 [65]	65 [35]	50 [25]	55 [30]	55 [30]	40 [20]	40 [20]	75 [45]	40 [25]
1 ¼"	36.0	DN 32	205 [120]	120 [70]	90 [50]	100 [60]	100 [55]	75 [45]	70 [40]	140 [80]	80 [45]
1 ½"	41.9	DN 40	285 [170]	165 [95]	125 [70]	140 [80]	140 [80]	105 [60]	100 [60]	190 [110]	110 [65]
2"	53.1	DN 50	470 [275]	270 [160]	205 [120]	235 [135]	225 [135]	170 [100]	165 [95]	315 [185]	180 [105]
2 ½"	68.9	DN 65	805 [475]	465 [275]	350 [205]	400 [235]	390 [230]	295 [170]	285 [165]	540 [320]	310 [180]
3"	80.9	DN 80	1120 [660]	645 [380]	485 [285]	555 [325]	540 [320]	405 [240]	400 [235]	750 [440]	430 [250]

* Nm³/h in acc. with DIN 1343: 0 °C, 1013.25 hPa for gases

** ISO 1217: 20 °C, 1000 hPa for air

6.2.2 Measuring range end values “Standard Version”

Measuring ranges standard version

Inside diameter of pipe			Standard version (92.7 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Air**	Nitrogen (N ₂)	Argon (Ar)	Oxygen (O ₂)	Carbon dioxide (CO ₂)	Methane natural gas (CH ₄)	Helium (He)	Hydrogen (H ₂)	Propane (C ₃ H ₈)
½"	16.1	DN 15	45 [25]	40 [20]	70 [40]	40 [25]	45 [25]	25 [15]	15 [11.1]	220 Nl/min [7.8]	20 [12.3]
¾"	21.7	DN 20	85 [50]	80 [45]	135 [80]	80 [45]	85 [50]	50 [30]	35 [20]	25 [15]	40 [20]
1"	27.3	DN 25	145 [85]	135 [75]	230 [135]	140 [80]	145 [85]	85 [50]	60 [35]	40 [25]	65 [35]
1 ¼"	36.0	DN 32	265 [155]	240 [140]	415 [245]	250 [145]	260 [155]	155 [90]	110 [65]	75 [45]	120 [70]
1 ½"	41.9	DN 40	365 [215]	335 [195]	570 [335]	345 [205]	360 [210]	215 [125]	150 [90]	105 [60]	165 [95]
2"	53.1	DN 50	600 [350]	550 [320]	935 [550]	570 [335]	590 [345]	355 [205]	250 [145]	175 [100]	275 [160]
2 ½"	68.9	DN 65	1025 [600]	945 [555]	1605 [945]	980 [575]	1015 [595]	605 [355]	425 [250]	300 [175]	470 [275]
3"	80.9	DN 80	1420 [835]	1305 [770]	2225 [1310]	1355 [795]	1405 [825]	840 [495]	595 [350]	415 [245]	650 [385]

Measuring ranges standard version (continued)

Inside diameter of pipe			Standard version (92.7 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Corgon @18	Forming gas 90% N ₂ + 10% H ₂	Natural gas (NG)	Biogas 50% CH ₄ + 50% CO ₂	Biogas 60% CH ₄ + 40% CO ₂	LPG 60% C ₃ H ₈ + 40% C ₄ H ₁₀	LPG 50% C ₃ H ₈ + 50% C ₄ H ₁₀	Nitrous oxide (N ₂ O)	Ethyne/ Acetylene (C ₂ H ₂)
½"	16.1	DN 15	65 [35]	35 [20]	25 [15]	30 [15]	30 [15]	20 [14.1]	20 [13.8]	40 [25]	25 [15]
¾"	21.7	DN 20	130 [75]	75 [40]	55 [30]	60 [35]	60 [35]	45 [25]	45 [25]	85 [50]	45 [25]
1"	27.3	DN 25	215 [125]	120 [70]	90 [55]	105 [60]	100 [60]	75 [45]	75 [45]	140 [85]	80 [45]
1 ¼"	36.0	DN 32	385 [225]	225 [130]	165 [95]	190 [110]	185 [110]	140 [80]	135 [80]	260 [150]	145 [85]
1 ½"	41.9	DN 40	535 [315]	310 [180]	230 [135]	265 [155]	260 [150]	195 [110]	190 [110]	355 [210]	205 [120]
2"	53.1	DN 50	875 [515]	505 [295]	380 [220]	435 [255]	425 [250]	315 [185]	310 [180]	585 [345]	335 [195]
2 ½"	68.9	DN 65	1500 [880]	865 [510]	650 [380]	745 [440]	725 [425]	545 [320]	535 [315]	1005 [590]	575 [335]
3"	80.9	DN 80	2075 [1220]	1205 [705]	900 [530]	1035 [605]	1005 [590]	755 [445]	740 [435]	1395 [820]	795 [470]

* Nm³/h in acc. with DIN 1343: 0 °C, 1013.25 hPa for gases

** ISO 1217: 20 °C, 1000 hPa for air

6.2.3 Measuring range end values “Max Speed Version”

Measuring ranges max version

Inside diameter of pipe			Max version (185.0 m/s)								
			Measuring range full scales in Nm ³ /h*/[cfm]								
Inch	mm	DN	Air**	Nitrogen (N ₂)	Argon (Ar)	Oxygen (O ₂)	Carbon dioxide (CO ₂)	Methane natural gas (CH ₄)	Helium (He)	Hydrogen (H ₂)	Propane (C ₃ H ₈)
1/2"	16.1	DN 15	90 [50]	80 [45]	140 [80]	85 [50]	90 [50]	50 [30]	35 [20]	25 [15]	40 [20]
3/4"	21.7	DN 20	175 [100]	160 [95]	275 [160]	165 [95]	175 [100]	105 [60]	70 [40]	50 [30]	80 [45]
1"	27.3	DN 25	290 [170]	270 [155]	460 [270]	280 [165]	290 [170]	170 [100]	120 [70]	85 [50]	135 [75]
1 1/4"	36.0	DN 32	530 [310]	485 [285]	830 [485]	505 [295]	525 [305]	310 [185]	220 [130]	155 [90]	240 [140]
1 1/2"	41.9	DN 40	730 [430]	670 [395]	1140 [670]	695 [410]	720 [425]	430 [250]	305 [180]	215 [125]	335 [195]
2"	53.1	DN 50	1195 [700]	1100 [645]	1870 [1100]	1140 [670]	1185 [695]	705 [415]	500 [290]	350 [205]	550 [320]
2 1/2"	68.9	DN 65	2050 [1205]	1885 [1110]	3205 [1885]	1955 [1150]	2030 [1190]	1210 [710]	855 [500]	600 [350]	940 [555]
3"	80.9	DN 80	2840 [1670]	2610 [1535]	4440 [2615]	2710 [1590]	2810 [1655]	1680 [985]	1185 [695]	830 [490]	1305 [765]

Measuring ranges max version (continued)

Inside diameter of pipe			Max version (185.0 m/s)								
			Measuring range full scales in Nm ³ /h*/[cfm]								
Inch	mm	DN	Corgon ®18	Forming gas 90% N ₂ + 10% H ₂	Natural gas (NG)	Biogas 50% CH ₄ + 50% CO ₂	Biogas 60% CH ₄ + 40% CO ₂	LPG 60% C ₃ H ₈ + 40% C ₄ H ₁₀	LPG 50% C ₃ H ₈ + 50% C ₄ H ₁₀	Nitrous oxide (N ₂ O)	Ethyne/Acetylene (C ₂ H ₂)
1/2"	16.1	DN 15	130 [75]	75 [45]	55 [30]	65 [35]	60 [35]	45 [25]	45 [25]	85 [50]	50 [30]
3/4"	21.7	DN 20	255 [150]	150 [85]	110 [65]	125 [75]	125 [70]	90 [55]	90 [50]	170 [100]	95 [55]
1"	27.3	DN 25	430 [250]	245 [145]	185 [110]	210 [125]	205 [120]	155 [90]	150 [90]	285 [170]	165 [95]
1 1/4"	36.0	DN 32	775 [455]	445 [260]	335 [195]	385 [225]	375 [220]	280 [165]	275 [160]	520 [305]	295 [175]
1 1/2"	41.9	DN 40	1065 [625]	615 [360]	460 [270]	530 [310]	515 [305]	385 [225]	380 [220]	715 [420]	410 [240]
2"	53.1	DN 50	1745 [1025]	1010 [595]	755 [445]	870 [510]	845 [495]	635 [375]	620 [365]	1170 [690]	670 [395]
2 1/2"	68.9	DN 65	2995 [1760]	1735 [1020]	1300 [765]	1490 [875]	1450 [855]	1090 [640]	1065 [625]	2010 [1180]	1150 [675]
3"	80.9	DN 80	4150 [2440]	2400 [1415]	1800 [1060]	2065 [1215]	2015 [1185]	1510 [890]	1480 [870]	2785 [1640]	1590 [935]

* Nm³/h in acc. with DIN 1343: 0 °C, 1013.25 hPa for gases

** ISO 1217: 20 °C, 1000 hPa for air

6.2.4 Measuring range end values “High-Speed Version”

Measuring ranges high-speed version

Inside diameter of pipe			High-speed version (224.0 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Air**	Nitrogen (N₂)	Argon (Ar)	Oxygen (O₂)	Carbon dioxide (CO₂)	Methane natural gas (CH₄)	Helium (He)	Hydrogen (H₂)	Propane (C₃H₈)
½"	16.1	DN 15	110 [60]	100 [55]	170 [100]	105 [60]	105 [60]	65 [35]	45 [25]	30 [15]	50 [25]
¾"	21.7	DN 20	215 [125]	195 [115]	335 [195]	205 [120]	210 [125]	125 [70]	85 [50]	60 [35]	95 [55]
1"	27.3	DN 25	355 [210]	325 [190]	555 [325]	340 [200]	350 [205]	210 [120]	145 [85]	100 [60]	160 [95]
1 ¼"	36.0	DN 32	640 [375]	590 [345]	1005 [590]	610 [360]	635 [370]	380 [220]	265 [155]	185 [110]	295 [170]
1 ½"	41.9	DN 40	885 [520]	815 [475]	1385 [815]	845 [495]	875 [515]	520 [305]	370 [215]	260 [150]	405 [235]
2"	53.1	DN 50	1450 [850]	1330 [780]	2265 [1330]	1380 [810]	1430 [840]	855 [500]	605 [355]	425 [250]	665 [390]
2 ½"	68.9	DN 65	2480 [1460]	2280 [1340]	3880 [2285]	2365 [1390]	2455 [1445]	1465 [865]	1035 [610]	725 [425]	1140 [670]
3"	80.9	DN 80	3440 [2025]	3165 [1860]	5380 [3165]	3280 [1930]	3405 [2000]	2035 [1195]	1435 [845]	1010 [590]	1580 [930]

Measuring ranges high-speed version (continued)


Inside diameter of pipe			High-speed version (224.0 m/s)								
			Measuring range full scales in Nm³/h*/[cfm]								
Inch	mm	DN	Corgon ®18	Forming gas 90% N₂ + 10% H₂	Natural gas (NG)	Biogas 50% CH₄ + 50% CO₂	Biogas 60% CH₄ + 40% CO₂	LPG 60% C₃H₈ + 40% C₄H₁₀	LPG 50% C₃H₈ + 50% C₄H₁₀	Nitrous oxide (N₂O)	Ethyne/Acetylene (C₂H₂)
½"	16.1	DN 15	160 [90]	90 [50]	65 [40]	80 [45]	75 [45]	55 [30]	55 [30]	105 [60]	60 [35]
¾"	21.7	DN 20	310 [185]	180 [105]	135 [80]	155 [90]	150 [85]	110 [65]	110 [65]	210 [120]	120 [70]
1"	27.3	DN 25	520 [305]	300 [175]	225 [130]	255 [150]	250 [145]	190 [110]	185 [105]	345 [205]	200 [115]
1 ¼"	36.0	DN 32	935 [550]	540 [320]	405 [240]	465 [275]	455 [265]	340 [200]	335 [195]	630 [370]	360 [210]
1 ½"	41.9	DN 40	1290 [760]	745 [440]	560 [330]	640 [375]	625 [365]	470 [275]	460 [270]	865 [510]	495 [290]
2"	53.1	DN 50	2115 [1245]	1225 [720]	920 [540]	1050 [620]	1025 [605]	770 [450]	755 [440]	1420 [835]	810 [475]
2 ½"	68.9	DN 65	3625 [2130]	2100 [1235]	1575 [925]	1805 [1060]	1760 [1035]	1320 [775]	1290 [760]	2435 [1430]	1390 [820]
3"	80.9	DN 80	5025 [2955]	2910 [1710]	2180 [1285]	2500 [1470]	2440 [1435]	1830 [1075]	1790 [1050]	3375 [1985]	1930 [1135]

* Nm³/h in acc. with DIN 1343: 0 °C, 1013.25 hPa for gases

** ISO 1217: 20 °C, 1000 hPa for air

7 Dimensions


7.1 Dimension KEC-2/KEC-4 Thread-version



KEC-2/KEC-4 thread version							
Connection thread	Outer pipe dia. [mm]	Inner pipe dia. [mm]	L [mm]	L1 [mm]	H [mm]	H1 [mm]	A [mm]
1/2"	21.3	16.1	300	210	176.4	165.7	20
3/4"	26.9	21.7	475	275	179.2	165.7	20
1"	33.7	27.3	475	275	182.6	165.7	25
1 1/4"	42.4	36	475	275	186.9	165.7	25
1 1/2"	48.3	41.9	475**	275	189.9	165.7	25
2"	60.3	53.1	475**	275	195.9	165.7	30

** Attention: Shortend inlet section! Please observe the recommended minimum inlet section (length = 10x inner diameter)

7.2 Dimension KEC-2/KEC-4 Flanged-version



KEC-2 flanged version									
							Flange DIN EN 1092-1		
Measuring section	Outer pipe dia. [mm]	Inner pipe dia. [mm]	L [mm]	L1 [mm]	H [mm]	H1 [mm]	ØD [mm]	ØK [mm]	n x ØL
DN 15	21,3	16,1	300	210	213,2	165,7	95	65	4 x 14
DN 20	26,9	21,7	475	275	218,2	165,7	105	75	4 x 14
DN 25	33,7	27,3	475	275	223,2	165,7	115	85	4 x 14
DN 32	42,4	36	475	275	235,7	165,7	140	100	4 x 18
DN 40	48,3	41,9	475**	275	240,7	165,7	150	110	4 x 18
DN 50	60,3	53,1	475**	275	248,2	165,7	165	125	4 x 18
DN 65	76,1	68,9	475	275	268,2	175,7	185	145	8 x 18
DN 80	88,9	80,9	475	275	275,7	175,7	200	160	8 x 18

** Attention: Shortened inlet section! Please observe the recommended minimum inlet section (length = 10x inner diameter)

8 Installation

8.1 Pipe/tube requirements


- Correctly sized gaskets
- Correct aligned flanges and gaskets
- Diameter mismatch at the pipe junctions should be avoided but must be less than 1mm. For further information see ISO 14511
- Ensure clean pipes after installation


8.2 Inlet / outlet runs

The principle of thermal Mass flow measurement is very sensitive against disturbances. Therefore, it is necessary to ensure the recommended inlet and outlet runs.

Table Inlet / Outlet runs

Flow obstruction before the measurement section	Min length Inlet run (L1)	Min length Outlet run (L2)
Slight curve (elbow < 90°)	12 x D	5 x D
Reduction (Pipe narrows to the measurement section)	15 x D	5 x D
Expansion (Pipe expands to the measurement section)	15 x D	5 x D
90° elbow or T-piece	15 x D	5 x D
2x elbow á 90° in einer Ebene	20 x D	5 x D
2x elbow á 90° 3-dimensional	35 x D	5 x D
Control valve	45 x D	5 x D





The values represent the min.lengths. In case the min. inlet / outlet runs could not be ensured, it must be expected to get increased or significant deviations of the measurement values.


8.2.1 Installation of KEC-2/KEC-4

The sensor KEC-2/KEC-4 is pre-supplied with the measuring section.

8.3 Alignment Display (Housing)

The sensor housing KEC-2/KEC-4 can be turned in both directions, max. 345 °. For this purpose, the housing-connecting nut must be opened. The housing can be rotated to the desired position, a bigger rotation angle is prevented by internal stop pins.

After that, the housing-connecting nut is firmly retighten



8.4 Tightening torques

To secure and guarantee of the function and tightness following tightening torques have to be applied, see table 1.

Table 1

Pos	Description	Tightening torque [Nm]
20	KEC-2/KEC-4 cover with glass	3
30	KEC-2/KEC-4 cover without window	3
50	Grub screw with hexagon socket M4x6 DIN 914 A2	2
130	KEC-2/KEC-4 nut	15
150	Cylinder screw DIN 6912 - M5x10 A2-70	4


9 Connection diagram

9.1 Cable glands - clamping ranges

For ensuring the tightness and strain relief, connector cables with the following diameters must be used.

KEC-2/KEC-4 Standard clamping range : Ø 5-9 mm

9.2 Connector pin assignment



Version with option board 2x analogue outputs galvanically isolated

Connector	Pin	Signal description
X1 Power supply	1	VB - (GND)
	2	VB+
X2 Modbus	1	Modbus (B)
	2	Modbus shield
	3	Modbus (A)
X4 Direction / Pulse	1	Pulse / Alarm *
	2	Pulse / Alarm *
	3	Direction input
	4	GND
X5 Current output 1	1	I- Active**
	2	I+ Active **
X6 Current output 2	1	I- Active **
	2	I+ Active **

* Outputs are galvanically isolated.


** The Current outputs, X5 and X6, are optional.(Active and passive version available).

9.3 Wire connection

9.3.1 General


- Wiring to be done in strainless state only.
- Length of cable skinning to be minimized
- Not used cable entries must be closed with end caps
- Use of cables with cross section of $\geq 0.25 \text{ mm}^2$

9.3.2 Power supply




9.3.3 Modbus RTU

If the sensor placed at the end of the Modbus system a termination is required. Therefore the enclosed 120R resistor is to be connected at Pin 1 and Pin 3 of connector „X2“




9.3.4 Pulse Output



10 Operation KEC-2/KEC-4

The operation of the KEC-2/KEC-4 are carried out by 2 optical keys through the glass cover. Thus, the KEC-2/KEC-4 can be operated from the outside without opening the cap.



Selection of the individual menu items is done by pressing the ">" and confirm by pressing "OK".

Inputs or changes can be made with all white deposit fields, selected field will be highlighted with yellow background.

Words in green font refer mainly to the pictures in the section of the chapter, but also on important menu paths or menu items that are related to are in green font.

The menu navigation is generally in a green font!


The table of contents and chapter references in blue font contain links to the respective chapter title.

10.1 Main menu (Home)


10.1.1 Initialization

After switching on the KEC-2/KEC-4 the initialized screen is displayed followed by the main menu.

10.2 Main menu



Switching to pages 2-4 or back by pressing key „□“



AV-Time (Period for average value calculation) could be changed under Sensor Setup.-Advanced– AV-Time

10.3 Settings


The settings menu could accessed by pressing the key „OK“.

But the access to the *settings menu* is password protected.



Factory settings for password at the time of delivery: 0000 (4 times zero).


If required the password could be changed at [Setup–User setup–Password](#).



Selection of a menu item or to change a value is done with the key „**△**“, a final move to the chosen menu item or takeover of the value change needs the confirmation by pressing the key „**OK**“

10.3.1 Sensor Setup

Setup → Sensor Setup





For changes, first select the menu item with key „**△**“ and then confirm it with „**OK**“.

10.3.1.1 Input / change tube diameter

For KEC-2/KEC-4 not adjustable (suspended) as voted on included measuring section with corresponding pipe diameter.

10.3.1.2 Input / change consumption counter

Setup → Sensor Setup → Total Counter → Unit button



In order to change, e.g. the unit, first select by pressing key „ Δ “ the button “Unit” and then key “OK”.

Select with the key „ Δ “ the correct unit and then confirm selection by pressing 2x „OK“.

Entering / changing the consumption counter via button „ Δ “, select the respective position and activate the position with the “OK” button.

By pressing „ Δ “ the position value is incremented by 1. Complete with “OK” and activate next number position.


Confirm entry by pressing „OK“.

Important!

When the counter reach 100000000 m³ the counter will be reset to zero.

10.3.1.3 Definition of the units for flow, velocity, temperature and pressure

Setup → Sensor Setup → Units







To make changes to the unit for the respective measurement value, first select by pressing „ Δ “ the field of the „measurement value“ and activate „it with „OK“.

Selection of the new unit with „ Δ “

In case the quantity of units selectable are not presentable on one page, please move to next page by pressing „<<“.

Confirm selection by pressing 2x „OK“.

Procedure for all 4 measurement-variables is analogous.




10.3.1.4 Definition of the reference conditions

Here can be defined the desired measured media reference conditions for pressure and temperature and times for the filter and averaging.

- Factory pre-setting for reference temperature and reference pressure are 20 °C, 1000 hPa
- All volume flow values (m³/h) and consumption values indicated in the display are related to 20 °C and 1000 hPa (according to ISO 1217 intake condition)
- Alternatively 0 °C and 1013 hPa (=standard cubic meter) can also be entered as a reference.
- **Do not enter the operation pressure or the operation temperature under reference conditions!**

Setup → Sensor Setup→ Advanced



To make changes, first select a menu with button „△“ and confirm selection by pressing „OK“.

Setup → Sensor Setup → Advanced → Ref.Pref

Ref. Pres
1000.00 hpa
CLR OK Cancel

In order to change, e.g. the unit, first select by pressing key „ Δ “ the field “**Units**” and then key “**OK**”.

Select with the key „ Δ “ the correct unit and then confirm selection by pressing 2x „**OK**“.

Input / change of the value by selecting the respective position with button „ Δ “ and entering by pressing button „**OK**“.

Setup → Sensor Setup → Advanced → Ref.Temp

Ref. Temp
20.0 °C
+/- CLR back

By pressing „ Δ “ the position value is incremented by 1. Complete with “**OK**” and activate next number position.

Procedure for changing the reference temperature is the same.

Setup → Sensor Setup → Advanced → Filtertime

Filtertime
200
CLR back

Under item “**Filtertime**” an attenuation can be defined.
Input values of 0 -10000 in [ms] are possible

Setup → Sensor Setup → Advanced → AV-Time

AV-Time
1
CLR OK Cancel


The time period for averaging can be entered here.

Input values of -1440 1 [minutes] are possible.

For average values see display window 3 + 4


10.3.1.5 Setting of Zeropoint and Low-flow cut off

Setup → Sensor Setup → ZP Adjust



To make changes, first select a menu with button „**△**“ and confirm selection by pressing „**OK**“.

Setup → Sensor Setup → ZP Adjust → ZeroPnt




When, without flow, the installed sensor shows already a flow value of > 0 m³/h herewith the zero point of the characteristic could be reset.

For an input / change of the value select with the button „**△**“ the respective number position and activate it with „**OK**“.

By pressing „**△**“ the position value is incremented by 1. Confirm the input with „**OK**“ and activate next number position.

Leave menu with button „**Back**“

Setup → Sensor Setup → ZP Adjust → CutOff




With the low-flow cut off activated, the flow below the defined "LowFlow Cut off" value will be displayed as 0 m³/h and not added to the consumption counter.

For an input / change of the value select with the button „**△**“ the respective number position and activate it with „**OK**“.

By pressing „**△**“ the position value is incremented by 1. Confirm the input with „**OK**“ and activate next number position.

Leave menu with button „**Back**“

Setup → Sensor Setup → ZP Adjust t → Reset



By selection of „**Reset**“ all settings for „**ZeroPnt**“ and. „**CutOff**“ are reset.

Menu item to be select with button „**△**“ and confirm the reset with „**OK**“.

Leave menu with button „**Back**“


10.3.2 Modbus Setup

The Flow sensors KEC-2/KEC-4 comes with a Modbus RTU Interface.
Before commissioning the sensor the communication parameters

- Modbus ID, Baudrate, Parity und Stop bit

must be set in order to ensure the communication with the Modbus master.

Settings → Modbus Setup



Default values out of factory: Modbus ID: 1

Baud rate: 19200

Stopbit: 1

Parity: even

Remark: If the sensor placed at the end of the Modbus system a termination is required.

Therefore the enclosed 120R resistor is to be connected at Pin 1 and Pin 3 of connector „X2“

10.3.2.1 Modbus Settings (2001...2005)

Modbus Register	Register Address	No.of Byte	Data Type	Description	Default Setting	Read Write	Unit /Comment
2001	2000	2	UInt16	Modbus ID	1	R/W	Modbus ID 1...247
2002	2001	2	UInt16	Baudrate	4	R/W	0 = 1200 1 = 2400 2 = 4800 3 = 9600 4 = 19200 5 = 38400
2003	2002	2	UInt16	Parity	1	R/W	0 = none 1 = even 2 = odd
2004	2003	2	UInt16	Number of Stopbits		R/W	0 = 1 Stop Bit 1 = 2 Stop Bit
2005	2004	2	UInt16	Word Order	0xABCD	R/W	0xABCD = Big Endian 0xCDAB = Middle Endian

10.3.2.2 Values Register (1001 ...1500)

Modbus Register	Register Address	No.of Byte	Data Type	Description	Default	Read Write	Unit /Comment
1101	1100	4	Float	Flow in m ³ /h		R	
1109	1108	4	Float	Flow in Nm ³ /h		R	
1117	1116	4	Float	Flow in m ³ /min		R	
1125	1124	4	Float	Flow in Nm ³ /min		R	
1133	1132	4	Float	Flow in ltr/h		R	
1141	1140	4	Float	Flow in Nltr/h		R	
1149	1148	4	Float	Flow in ltr/min		R	
1157	1156	4	Float	Flow in Nltr/min		R	
1165	1164	4	Float	Flow in ltr/s		R	
1173	1172	4	Float	Flow in Nltr/s		R	
1181	1180	4	Float	Flow in cfm		R	
1189	1188	4	Float	Flow in Ncfm		R	
1197	1196	4	Float	Flow in kg/h		R	
1205	1204	4	Float	Flow in kg/min		R	
1213	1212	4	Float	Flow in kg/s		R	
1221	1220	4	Float	Flow in kW		R	

Modbus Register	Register Address	No.of Byte	Data Type	Description	Default	Read Write	Unit /Comment
1269	1268	4	UInt32	Consumption m ³ before comma	x	R	
1275	1274	4	UInt32	Consumption Nm ³ before comma	x	R	
1281	1280	4	UInt32	Consumption ltr before comma	x	R	
1287	1286	4	UInt32	Consumption NLtr before comma	x	R	
1293	1292	4	UInt32	Consumption cf before comma	x	R	
1299	1298	4	UInt32	Consumption Ncf before comma	x	R	
1305	1304	4	UInt32	Consumption kg before comma	x	R	
1311	1310	4	UInt32	Consumption kWh before comma	x	R	
1347	1346	4	Float	Velocity m/s			
1355	1354	4	Float	Velocity Nm/s			
1363	1362	4	Float	Velocity Ft/min			
1371	1370	4	Float	Velocity NFt/min			
1419	1418	4	Float	GasTemp °C			
1427	1426	4	Float	GasTemp °F			

Remark:

For more additional Modbus values please refer to the separate Operating Instructions Modbus Installation and Operating Instructions for the sensors KEC-1 and KEC-2/KEC-4.

10.3.3 Pulse /Alarm

Setup → Sensor Setup → Pulse/ Alarm

Relay Mode:	Alarm
Unit	°C
Value	20.0
Hyst.	5.0
Hi-Lim.	OK Cancel

*** Pulse / Alarm ***	
Relay Mode:	Alarm
Unit:	°C
Value	20.0
Hyst.	5.0
Hi-Lim.	OK Cancel

*** Pulse / Alarm ***	
Relay Mode:	Pulse
Unit:	m ³
Value	0.1
Polarity	pos.
Pls per second at max Speed:	0
Back	

The galvanically isolated output can be defined as pulse- or alarm output.

Selection of field „**Relay Mode**“ with key „**△**“ and change modus by pressing key „**OK**“.

For alarm output following units could be chosen: kg/min, cfm, ltr/s, m³/h, m/s, °F, °C and kg/s.

„**Value**“ defines the Alarm value, „**Hyst.**“ defines the desired hysteresis and with „**Hi-Lim**“ or. „**Lo-Lim**“ the alarm settings when the alarm is activated

Hi-Lim: Value over limit


Lo-Lim: Value under limit

For the pulse output following units could be chosen: kg, cf, ltr and m³.

The pulse value definition to be done in menu „**Value**“ (0.1, 1, 10, 100).

With „**Polarity**“ the switching state could be defined.

Pos. = 0 → 1 neg. 1 → 0



10.3.3.1 Pulse output

The maximum frequency for pulse output is 50 pulses per second (50Hz). The Pulse output is delayed by 1 second.


Pulse value	[m ³ /h]	[m ³ /min]	[l/min]
0.1 ltr / Pulse	1,8	0,3	300
1ltr / Pulse	18	3	3000
0.1m ³ / Pulse	18000	300	300000
1 m ³ / Pulse	180000	3000	3000000

Table 1 Maximum flow for pulse output

Entering pulse values that are not allow a presentation to the full scale value, are not allowed. Entries are discarded and error message displayed.

10.3.4 User Setup

Settings → UserSetup



To make changes, first select a menu with button „ Δ “ and confirm selection by pressing „OK“.

It is possible to define a password. The required password length is 4 digits.

Please select with button „ Δ “ a figure and confirm it with „OK“. Repeat this 4 times.

With „ $<$ “ the last figure could be deleted.

Password input have to be inserted twice.

Confirmation of input/password by pressing „OK“.

With „**Brightness**“ it is possible to adjust the backlight / display brightness.

By activation “**Dimming after**” and entering a time a display dimming could be set.


With „**Rotate Screen**“ the display information could be rotated by 180°.

Currently 4 languages have been implemented and could be selected with button „ Δ “.

Change of language by confirming with “OK”. Leaving the menu with button “back”.

10.3.5 Advanced


Settings → Advanced



By pressing „**Factory Reset**“ the sensor is set back to the factory settings.


10.3.6 4 -20mA

Settings → 4-20mA



To make changes, first select a menu with button „△“ and confirm selection by pressing „OK“.

Settings → 4-20mA → Channel 1



The 4-20 mA Analogue output of the Sensor KEC can be individually adjusted.

It is possible to assign following values „Temperature“, „Velocity“ und „Flow“ to the channel CH 1.



To make changes, first select the value item with button „△“ and confirm

Moving between the different measurements values or to deactivate the 4-20mA with setting to „unused“ by pressing „OK“.

To the selected measurement value a corresponding / appropriate unit needs to be defined. Select „Unit“ with „△“ and open menu with „OK“.


Select required unit with „△“ and take over by pressing „OK“.

Here e.g. for the measurement value Flow, procedure for the other measurements values is analog.



For saving the changes done press button „Save“ to discard the changes press button „Cancel“.

Leaving the menu with „Back“.

Settings → 4-20mA → Channel 1 → AutoRange

The scaling of the 4-20mA channel can be done automatically "Auto Range = on" or manual "AutoRange = off".

With button „**△**“ select the menu item „AutoRange“ select with „**OK**“ the desired scaling method.
(Automatically or manually)

In case of **AutoRange = off** with „**Scale 4mA**“ und „**Scale 20mA**“ the scale ranges needs to be defined.


Select with button „**△**“ the item „Scale 4mA“ or „Scale 20mA“ and confirm with „**OK**“.

Input of the scaling values will be analogous as described before for value settings.

Using „**CLR**“ clears up the complete settings at once.

For „**Auto on**“, the max. scaling is calculated based on the inner tube diameter, max. measurement range and the reference conditions settings.

Take over of the inputs with „**Save**“ and leaveing the menu with „**Back**“.

Settings → 4-20mA → Error Current

This determines what is output in case of an error at the analog output.

- 2 mA Sensor error / System error
- 22 mA Sensor error / System error
- None Output according Namur (3.8mA – 20.5 mA)
< 4mA to 3.8 mA Measuring range under range
>20mA to 20.5 mA Measuring range exceeding


To make changes first select a menu item "Current Error" with button „**△**“ and then select by pressing the „**OK**“ the desired mode

For saving the changes done press button „**Save**“ to discard the changes press button „**Cancel**“.

Leaving the menu with „**Back**“.

10.3.7 KEC-2/KEC-4 Info

Setup → Sensor Setup → Info



Here you get a brief description of the sensor data incl. the calibration data.

Under **Details**, you are able to see in addition the calibration conditions.


11 Disposal

Note!

- Avoid environmental damage caused by media-contaminated parts
- Dispose of the device and packaging in an environmentally friendly manner
- Comply with applicable national and international disposal regulations and environmental regulations.

Batteries

Batteries containing pollutants are marked with a sign consisting of a crossed-out garbage can and the chemical symbol (Cd, Hg, Li or Pb) of the heavy metal that is decisive for the classification as containing pollutants:



1. „Cd“ stands for cadmium
2. „Hg“ stands for mercury
3. „Pb“ stands for lead
4. „Li“ stands for lithium

Electrical and electronic equipment



12 EU Declaration of Conformance

We, KOBOLD Messring GmbH, Nordring 22-24, 65719 Hofheim, Germany, declare under our sole responsibility that the product:

Thermal Mass Flowmeter for gases

Model: KEC-2/KEC-4

to which this declaration relates is in conformity with the following EU directives stated below:

2014/30/EU	EMC Directive
2011/65/EU	RoHS
2015/863/EU	Delegated Directive (RoHS III)
2014/68/EU	PED (from DN32)

	Fluid group	
	Group I dangerous fluids	Group 2 not dangerous fluids
KEC-2/KEC-4... Nominal size: DN32-DN50 Nominal pressure: PN16	category I, module A	Art. 4, Para. 3
KEC-2/KEC-4... Nominal size: DN32-DN80 Nominal pressure: PN40	-	category I, module A

Also, the following standards are fulfilled:

EN 55011:2016 + A1:2017 Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements

EN IEC 63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

Additionally for KEC-2/KEC-4 with nominal size: DN32-DN50 and nominal pressure: PN16, as well as with nominal size DN32-DN80 and nominal pressure: PN40:

DIN EN ISO 5817:2014 Welding - Fusion-welded joints in steel, nickel, titanium and their alloys (beam welding excluded) - Quality levels for imperfections

DIN EN 10217-7 Welded steel tubes for pressure purposes - Technical delivery conditions - Part 7: Stainless steel tubes

DIN EN 1092-1:2018 Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 1: Steel flanges

DIN EN ISO 17637 Non-destructive testing of welds - Visual testing of fusion-welded joints

Hofheim, 30 Jan. 2024



H. Volz J. Burke
General Manager Compliance Manager

13 UK Declaration of Conformity

We, KOBOLD Messring GmbH, Nordring 22-24, 65719 Hofheim, Germany, declare under our sole responsibility that the product:

Thermal Mass Flowmeter for gases

Model: KEC-2/KEC-4

to which this declaration relates is in conformity with the following UK directives stated below:

S.I. 2016/1091	Electromagnetic Compatibility Regulations 2016	
S.I. 2012/3032	The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012	
S.I. 2016/1105	Pressure Equipment (Safety) Regulations 2016 (from DN32)	

	Fluid group	
	Group I dangerous fluids	Group 2 not dangerous fluids
KEC-2... Nominal size: DN32-DN50 Nominal pressure: PN16	category I, module A	Art. 4, Para. 3
KEC-2... Nominal size: DN32-DN80 Nominal pressure: PN40	-	category I, module A

Also, the following standards are fulfilled:

BS EN 55011:2016 + A1:2017 Industrial, scientific and medical equipment. Radio-frequency disturbance characteristics. Limits and methods of measurement

BS EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements

BS EN IEC 63000:2018

Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.

Additionally for **KEC-2** with nominal size: DN32-DN50 and nominal pressure: PN16, as well as with nominal size DN32-DN80 and nominal pressure: PN40:


BS EN ISO 5817:2014 – TC Welding. Fusion-welded joints in steel, nickel, titanium and their alloys (beam welding excluded). Quality levels for imperfections

BS EN 10217-7 Welded steel tubes for pressure purposes. Technical delivery conditions Stainless steel tubes

BS EN 1092-1:2018 Flanges and their joints. Circular flanges for pipes, valves, fittings and accessories, PN designated. Steel flanges

BS EN ISO 17637 Non-destructive testing of welds. Visual testing of fusion-welded joints

Hofheim, 30 Jan. 2024



H. Volz J. Burke
General Manager Compliance Manager