



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

UMC3-abcd31 Coriolis Mass Flow Transmitter Integral Mount
XP-AIS/ / / 1 / CD / T*: CD06101

a = Mounting, A or B
b = Display/Interface Board 0, 1 or 2
c = Power Supply 1 or 2
d = Outputs A, B, C, D or E
* See drawing: CD06101

Special condition of Use

1. When used with Heinrichs TM, TMU or TME Coriolis Mass Flow Sensors

TM – ab-cd-efgh-A-j-k Coriolis Mass Flow Meter Integral Mount
IS / / / 1 / ABCD / T*: CD06101

a = Wetted materials S, H, or T
b = Meter Line Size, when a = S: 01, 04, 07, 10, 13, 19, 25, 34, 40, 49, 55 or XX;
when a = H: 22, 25, 34, 40, 49, 55 or XX;
when a = T: 23, 28, 37, 43, 46, 54 or XX
c = Process connection 101C, 105C, 109C, 117C, 121C, 131C, 135C, 140C, 145C, 150C,
155C, 156C, 162C, 169C, 175C, 101N, 105N, 105E, 109N, 109E, 116N, 121N, 121E, 131N,
131E, 135N, 140N, 145N, 150N, 155N, 156N, 162N, 169N, 175N, 6010, 6030, 201R, 241R,
202R, 202F, 222F, 242R, 203R, 203F, 243R, 205R, 245R, 206R, 206F, 246R, 208R, 208F,
248R, 210R, 230R, 250R, 212R, 232R, 252R, 213R, 233R, 253R, 214R, 234R, 254R, 215R,
235R, 255R, 216R, 236R, 256R, 217R, 226F or XXXX
d = Overall length 0000 or XXXX
e = Containment Options A, E, F, R, K, S, W or X
f = Heating/cooling 0, 1, 2, 3, 4, 5 or X
g = Flow direction U, O, L or R
h = Transmitter Interface 1 or 2
j = Certificate 0, 1, 2, B or C
k = Accessory 0 or X
* See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Transmitter

TME – Sabcd-A-f-g Coriolis Mass Flow Meter Integral Mount
IS / / / 1 / ABCD / T*: CD06101

a = Range Process Connections 13-101C, 13-101N, 13-201R, 13-221R, 16-101C, 16-101N,

16-201R, 16-221R, 25-105C, 25-105N, 25-202R, 31-105C, 31-105N, 31-202R, 34-109C, 34-109N, 34-203R, 34-223R, 40-109C, 40-109N, 40-203R, 40-223R, 49-121C, 49-121N, 49-206R, 49-226R, 55-131C, 55-131N, 55-208R, 55-228R, 58-131C, 58-131N, 58-208R or 58-228R

b = Heating/cooling 0, 1, 2 or 3
 c = Flow direction U, O, L or R
 d = Transmitter Interface 1 or 2
 f = Certificate 0, 1, 2, B or C
 g = Supplementary Equipment 0 or X
 * See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Transmitter

TMU- ab-c-def-gA-ij-k Coriolis Mass Flow Meter Integral Mount

IS / I / 1 / ABCD / T*: CD06101

a = Wetted Materials S or H
 b = Meter Line Size 008, 010, 015, 025, 040, 050, 080, 100, 150, 200, 250 or 300
 c = Process connection 6010, 6030, 101C, 105C, 109C, 117C, 121C, 131C, 135C, 140C, 145C, 150C, 155C, 156C, 162C, 169C, 175C, 101N, 105N, 109N, 116N, 117N, 121N, 131N, 135N, 140N, 145N, 150N, 155N, 156N, 162N, 169N, 175N, 6010, 6030, 201R, 226R, 241R, 202R, 242R, 203R, 243R, 205R, 245R, 206R, 246R, 208R, 248R, 210R, 230R, 250R, 212R, 232R, 252R, 213R, 233R, 253R, 214R, 234R, 254R, 215R, 235R, 255R, 216R, 236R, 256R, 217R, 225R, 226C, 246C or XXXX
 d = Containment Options A, B or X
 e = Heating/cooling 0, A or B
 f = Connection for the heating 0, A, B, C, D, E, F, G, H or X
 g = Transmitter interface A or B
 i = Calibration mass flow 1, 2, 3 or X
 j = Calibration density 0, 1, 2 or X
 k = Accessory 0 or X
 * See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Transmitter

UMC3-abcd31 Coriolis Mass Flow Transmitter Remote Mount

XP-AIS/ I / 1 / CD / T*: CD06101

a = Mounting C, D, E or F
 b = Display/Interface Board 0, 1, or 2
 c = Power Supply 1 or 2
 d = Outputs A, B, C, D or E

* See drawing: CD06101

Special condition of Use

1. When used with Heinrichs TM, TMU or TME Coriolis Mass Flow Sensors

TM – ab-cd-efgh-A-j-k Coriolis Mass Flow Remote Mount

IS / I / 1 / ABCD / T*: CD06101

a = Wetted materials S, H, or T
 b = Meter Line Size, when a = S: 01, 04, 07, 10, 13, 19, 25, 34, 40, 49, 55 or XX
 when a = H: 22, 25, 34, 40, 49, 55 or XX;
 when a = T: 23, 28, 37, 43, 46, 54 or XX:
 c = Process connection 101C, 105C, 109C, 117C, 121C, 131C, 135C, 140C, 145C, 150C, 155C, 156C, 162C, 169C, 175C, 101N, 105N, 105E, 109N, 119E, 116N, 121N, 121E, 131N, 131E, 135N, 140N, 145N, 150N, 155N, 156N, 162N, 169N, 175N, 6010, 6030, 201R, 241R, 202R, 202F, 222F, 242R, 203R, 203F, 243R, 205R, 245R, 206R, 206F, 246R, 208R, 208F,

248R, 210R, 230R, 250R, 212R, 232R, 252R, 213R, 233R, 253R, 214R, 234R, 254R, 215R, 235R, 255R, 216R, 236R, 256R, 217R, 226F or XXXX

- d = Overall length 0000 or XXXX
- e = Containment Options A, E, F, R, K, S, W or X
- f = Heating/cooling 0, 1, 2, 3, 4, 5 or X
- g = Flow direction U, O, L or R
- h = Transmitter Interface 3, 4, 5, 6, 7 or 8
- j = Certificate 0, 1, 2, B or C
- k = Accessory 0 or X
- * See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Remote Transmitter

TME – Sabcd-A-e-f Coriolis Mass Flow Remote Mount

IS / / / / ABCD / T*: CD06101

- a = Range Process/Connections 13-101C, 13-101N, 13-201R, 13-221R, 16-101C, 16-101N, 16-201R, 16-221R, 25-105C, 25-105N, 25-202R, 31-105C, 31-105N, 31-202R, 34-109C, 34-109N, 34-203R, 34-223R, 40-109C, 40-109N, 40-203R, 40-223R, 49-121C, 49-121N, 49-206R, 49-226R, 55-131C, 55-131N, 55-208R, 55-228R, 58-131C, 58-131N, 58-208R, 58-228R
- b = Heating/cooling 0, 1 2 or 3
- c = Flow direction U, O, L or R
- d = Transmitter Interface 3, 4, 6 or 7
- e = Certificate 0, 1, 2 B or C
- f = Accessory 0 or X
- * See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Remote Transmitter

TMU- ab-c-def-gA-ij-k Coriolis Mass Flow Remote Mount

IS / / / / ABCD / T*: CD06101

- a = Wetted Materials S or H
- b = Meter Line Size 008, 010, 015, 025, 040, 050, 080, 100, 150, 200, 250 or 300
- c = Process connection 6010, 6030, 101C, 105C, 109C, 117C, 121C, 131C, 135C, 140C, 145C, 150C, 155C, 156C, 162C, 169C, 175C, 101N, 105N, 109N, 116N, 117N, 121N, 131N, 135N, 140N, 145N, 150N, 155N, 156N, 162N, 169N, 175N, 6010, 6030, 201R, 226R, 241R, 202R, 242R, 203R, 243R, 205R, 245R, 206R, 246R, 208R, 248R, 210R, 230R, 250R, 212R, 232R, 252R, 213R, 233R, 253R, 214R, 234R, 254R, 215R, 235R, 255R, 216R, 236R, 256R, 217R, 225R, 226C, 246C or XXXX
- d = Containment Options A, B or X
- e = Heating/cooling 0 or A
- f = Connection for the heating 0, A, B, C, D, E, F, G, H or X
- g = Transmitter interface C, D, E, F, G, H, J, K, L or M
- i = Calibration mass flow 1, 2, 3 or X
- j = Calibration density 0, 1, 2 or X
- k = Accessory 0 or X
- * See drawing: CD06101

Special condition of Use

1. When used with Heinrichs UMC3 Coriolis Mass Flow Remote Transmitter



Member of the FM Global Group

Equipment Ratings:

UMC3 – Explosionproof for Class I Division 1 Groups C and D Hazardous Locations with intrinsically safe outputs for connection to Class I Division 1 Groups A, B, C and D Hazardous Apparatus.

TM, TME and TMU – Intrinsically Safe for use in Class I Division 1 Groups A, B, C and D Hazardous Locations.

FM Approved for:

Heinrichs Messtechnik GmbH
Köln, Germany D-50739

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 0.4	1982
CSA C22.2 No. 0.5	1982
CSA C22.2 No. 30	1988
CSA C22.2 No. 94	1991
CSA C22.2 No. 142	1990
CSA C22.2 No. 157	1992


Original Project ID: 3023373C

Approval Granted: December 7, 2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
020107	<i>21 JUNE 2007</i>		

FM Approvals LLC



Roger L. Allard
Assistant Vice President

21 JUNE 2007

Date